

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7320-0067:216 Page 1 of 1

**CATEGORY:** Speakers

**LISTEE:** Siemens Building Technologies Inc., \*Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932  
Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

**DESIGN:** Speakers, Models S-LP25, S-LP25-W, S-LP25-C, S-LP70, S-LP70-W, S-LP70-C.

Speaker/Strobes, Models S-LP25-S17, -S30, -S60, -S75, -S110, -S17S, -S30S, -S60S, -S75S, -S110S; S-LP25-S17-W, -S30-W, -S60-W, -S75-W, -S110-W, -S17S-W, -S30S-W, -S60S-W, -S75S-W, -S110S-W; S-LP25-S17-C, -S30-C, -S60-C, -S75-C, -S110-C, -S17S-C, -S30S-C, -S60S-C, -S75S-C, -S110S-C; S-LP70-S17, -S30, -S60, -S75, -S110, -S17S, -S30S, -S60S, -S75S, -S110S; Models S-LP25-MCS, S-LP25-MCS-W, S-LP25-MCS-C speaker/selectable candela strobes.

Speaker/Strobes, Models S-LP70-S17-W, -S30-W, -S60-W, -S75-W, -S110-W, -S17S-W, -S30S-W, -S60S-W, -S75S-W, -S110S-W; S-LP70-S17-C, -S30-C, -S60-C, -S75-C, -S110-C, -S17S-C, -S30S-C, -S60S-C, -S75S-C, -S110S-C, Models S-LP70-MCS, S-LP70-MCS-W, S-LP70-MCS-C speaker/selectable candela strobes.

Units are cone type speaker assembly which are available in 25 Vrms and 70.7 V rms versions. The wattage taps available at 1/4W, 1/2W, 1W and 2W. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Electrical: 25 Vrms and 70.7 Vrms  
Candela: 15 cd, 30 cd, 60 cd, 75 cd, 110 cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical, candela, audibility rating, and UL label.

**APPROVAL:** Listed as speakers, speaker/strobes and speaker/selectable candela strobes for use with separately listed compatible fire alarm control units. Models with suffix -W are for wall mount and suffix -C are for ceiling mount. For indoor use only. Models with strobe are also suitable for the hearing impaired applications. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to listee's Installation Instructions Manual for details.

**XLF:** 7320-0065:167

\*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**OCTOBER 26, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager